

CERTIFICATE REGARDING SAFE DRINKING WATER & SANITARY CONDITION

Dispatch No : 1223

Date : 01-06-2026

Certified that an inspection team headed by Er. Guriqbal Singh SDE & Maninderpal Singh JE from W/S & Sanitation Department Sub Division Sunam inspected **Punjab Convent School, Mehlan** Distt Sangrur on 08.05.2026 and found that **Punjab Convent School, Mehlan** has safe drinking water facilities for the students and members of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms and reports. This certificate is valid upto 31-03-2027.

Makham Singh

President
Punjab Convent School
Education Society
MEHLAN (Sangrur)

[Signature]
Sub Divisional Engineer
W/S and Sanitation Sub Div
Sunam

[Signature]
Principal,
Punjab Convent School,
MEHLAN (Sangrur)
Affi. No. 1630821

REGIONAL WATER TESTING LAB, SANGRUR

Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur
rwtlsangrur@gmail.com

To,

Punjab Convent School
V.P.O. Mehlan

No.: RWTL/SNG/2627/00059 Dated : 25/04/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 07/26 Dated: 09/04/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 23/04/2026. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Sangrur


D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab
Sangrur



President
Punjab Convent School
V.P.O. Mehlan
MEHLAN (Sangrur)



Principal,
Punjab Convent School,
MEHLAN (Sangrur)
Affi. No. 1630821



REGIONAL WATER TESTING LAB, SANGRUR
Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur
rwtlsangrur@gmail.com

TEST REPORT						
Name & Address of Customer : Punjab Convent School V.P.O. Mehlan			Customer Reference No.		No : 07/26 Dated : 09/04/2026	
			Sample Submitted by			
			Date of Sample Receipt		23/04/2026	
			Analysis Starting Date		23/04/2026	
			Analysis completion Date		25/04/2026	
Discipline : Chemical Testing, Bacteriological Testing			Group: Water			
ULR No.:				Sample Type :		Water
Test Report No.:		RWTL/SNG/2627/00059		Date of Issue :		25/04/2026
Registration no.:		RWTL/SNG/REG2627/00144		Condition of Sample :		Unsealed
Collection Point:		Private Submersible		Quantity/Type of Bottle:		1000 ml / Plastic Bottles
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		NA / NA
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Not Mentioned		District :		Sangrur
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.12	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	AGREEABLE	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	TDS	162	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
5	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
6	T. Alkalinity(CaCO ₃)	120	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
7	T. Hardness(CaCO ₃)	80	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
8	Calcium(Ca)	13	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
9	Magnesium(Mg)	12	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
10	Chloride(Cl)	20	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
11	Iron(Fe)	BDL	1.0	No Relaxation	mg/l	Spectrophotometric Method
12	Sulphate(SO ₄)	BDL	200	400	mg/l	Spectrophotometric Method
13	Fluoride(F)	BDL(0.05)	1.0	1.5	mg/l	APHA 4500 F-(23rd Ed. 2017)/IS-3025 (Part-60)

Continue on next page...

Reviewed and Approved By

[Signature]

Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab
Sangrur

[Signature]
President
Punjab Convent School
Education Society
MEHLAN (Sangrur)

[Signature]
Principal,
Punjab Convent School,
MEHLAN (Sangrur)
Aff. No. 1630621



REGIONAL WATER TESTING LAB, SANGRUR

Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur
rwtsangrur@gmail.com

14	Nitrate(NO3)	<5	45	No Relaxation	mg/l	Spectrophotometric Method/ APHA 4500 NO3- (23rd Ed. 2017)
15	Arsenic(As)	BDL(0.005)	0.01	No relaxation	mg/l	Spectrophotometric Method/ Colorimetric Method
16	Total Coliform(TC)	Absent	Shall not be detectable in any 100 ml sample	No relaxation	---	IS 15185 Membrane Filtration Method
17	E-Coli	Absent	Shall not be detectable in any 100 ml sample	No relaxation	---	IS 15185 Membrane Filtration Method

This Report is issued under the following terms & Condition :


1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: $25 \pm 5^{\circ}\text{C}$ and Humidity condition limit: $50 \pm 20\%$

Reviewed and Approved By



Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab
Sangrur

End of the Test Report



Principal
Punjab Convent School
MEHLAN (Sangrur)



Principal,
Punjab Convent School,
MEHLAN (Sangrur)
Affi. No. 1630821

